

Product datasheet: Mechanical ventilation unit to Regulation (EU) No. 1254/2014 | 1253/2014

		VLR 70 L Trend EN
		201458
Manufacturer		STIEBEL ELTRON
Specific energy consumption under colder climate conditions with control subject to on-site requirements	kWh/(m²a)	-87,86
Specific energy consumption under average climate conditions with control subject to on-site requirements	kWh/(m²a)	-43,91
Specific energy consumption under warmer climate conditions with control subject to on-site requirements	kWh/(m²a)	-18,74
Energy efficiency class under colder climate conditions with control subject to on-site requirements		A+
Energy efficiency class under average climate conditions with control subject to on-site requirements		A+
Energy efficiency class under warmer climate conditions with control subject to on-site requirements		E
Ventilation unit type		WLA, Zwei Richtungen
Drive type		Drehzahl geregelt
Heat recovery type		Regenerativ
Rate of temperature change for heat recovery	%	86,6
Max. air flow rate	m³/h	70
Max. power consumption	W	12
Sound power level LWA	dB(A)	47
Reference air flow rate	m³/s	0,014
Reference pressure differential	Pa	50
Specific power input	W/(m³/h)	0,14
Control factor, control subject to on-site requirements		0,65
External air leakage quota	%	2,40
Filter change indicator		Visual filter change warning signal on the remote control display. Please note that regular filter changes are important for good system energy efficiency
Instructions for controllable outdoor air grilles with ELA		not applicable
Sensitivity to pressure fluctuations	%	22,9 / 22,9
Airtightness between indoors and outdoors	m³/h	0,20
Annual power consumption under colder climate conditions with control subject to on-site requirements	kWh/a	82
Annual power consumption under average climate conditions with control subject to on-site requirements	kWh/a	82
Annual power consumption under warmer climate conditions with control subject to on-site requirements	kWh/a	82
Annual heating savings under colder climate conditions with control subject to on-site requirements	kWh/a	8990
Annual heating savings under average climate conditions with control subject to on-site requirements	kWh/a	4595
Annual heating savings under warmer climate conditions with control subject to on-site requirements	kWh/a	2078