

Required details about room heater and combi heater with heat pump to regulation (EU) no. 813/2013 & 811/2013

| | | WPL 13 ACS classic UK compact Set S | |
|---|----|-------------------------------------|------|
| | | 239115 | |
| Manufacturer | | STIEBEL ELTRON | |
| Heat source | | Outside air | |
| Low temperature heat pump | | | - |
| With booster heater | | | x |
| Combi boiler with heat pump | | | x |
| Rated heating output in colder climates for average temperature applications (Prated) | kW | | 11 |
| Rated heating output in moderate climates for average temperature applications (Prated) | kW | | 8 |
| Rated heating output in warmer climates for average temperature applications (Prated) | kW | | 6 |
| Tj = -7 °C heating output, partial load range in colder climates (Pdh) | kW | | 6.6 |
| Tj = -7 °C heating output, partial load range under moderate climatic conditions (Pdh) | kW | | 5.1 |
| Tj = 2 °C heating output, partial load range in colder climates (Pdh) | kW | | 4.0 |
| Tj = 2 °C heating output, partial load range under moderate climatic conditions (Pdh) | kW | | 4.1 |
| Tj = 2 °C heating output, partial load range in warmer climates (Pdh) | kW | | 6.0 |
| Tj = 7 °C heating output, partial load range in colder climates (Pdh) | kW | | 2.7 |
| Tj = 7 °C heating output, partial load range under moderate climatic conditions (Pdh) | kW | | 2.6 |
| Tj = 7 °C heating output, partial load range in warmer climates (Pdh) | kW | | 3.9 |
| Tj = 12 °C heating output, partial load range in colder climates (Pdh) | kW | | 3.4 |
| Tj = 12 °C heating output, partial load range under moderate climatic conditions (Pdh) | kW | | 3.3 |
| Tj = 12 °C heating output, partial load range in warmer climates (Pdh) | kW | | 3.3 |
| Tj = dual mode temperature in colder climates (Pdh) | kW | | 6.6 |
| Tj = dual mode temperature under moderate climatic conditions (Pdh) | kW | | 6.1 |
| Tj = dual mode temperature in warmer climates (Pdh) | kW | | 6.0 |
| Tj = operating temperature limit in colder climates (Pdh) | kW | | 1.8 |
| Tj = operating temperature limit under moderate climatic conditions (Pdh) | kW | | 5.1 |
| Tj = operating temperature limit in warmer climates (Pdh) | kW | | 6.0 |
| For air/water heat pumps: Tj = -15 °C (if TOL < -20 °C) (Pdh) | kW | | 0.0 |
| Dual mode temperature in colder climates (Tbiv) | °C | | -7 |
| Dual mode temperature in moderate climates (Tbiv) | °C | | -5 |
| Dual mode temperature in warmer climates (Tbiv) | °C | | 2 |
| Seasonal room heating efficiency in colder climates for average temperature applications (ηs) | % | | 103 |
| Seasonal room heating efficiency in moderate climates for average temperature applications (ηs) | % | | 125 |
| Seasonal room heating efficiency in warmer climates for average temperature applications (ηs) | % | | 153 |
| Tj = -7 °C COP, partial load range in colder climates (COPd) | | | 2.40 |
| Tj = -7 °C COP, partial load range under moderate climatic conditions (COPd) | | | 2.00 |
| Tj = 2 °C COP, partial load range in colder climates (COPd) | | | 3.60 |
| Tj = 2 °C COP, partial load range under moderate climatic conditions (COPd) | | | 3.30 |
| Tj = 2 °C COP, partial load range in warmer climates (COPd) | | | 2.20 |
| Tj = 7 °C COP, partial load range in colder climates (COPd) | | | 5.00 |
| Tj = 7 °C COP, partial load range under moderate climatic conditions (COPd) | | | 4.60 |
| Tj = 7 °C COP, partial load range in warmer climates (COPd) | | | 3.20 |
| Tj = 12 °C COP, partial load range in colder climates (COPd) | | | 6.20 |
| Tj = 12 °C COP, partial load range under moderate climatic conditions (COPd) | | | 6 |
| Tj = 12 °C COP, partial load range in warmer climates (COPd) | | | 5.70 |
| Tj = dual mode temperature in colder climates (COPd) | | | 2.40 |
| Tj = dual mode temperature under moderate climatic conditions (COPd) | | | 2.30 |

| | | |
|---|---|----------|
| Tj = dual mode temperature in warmer climates (COPd) | | 2.20 |
| Tj = operating temperature limit in colder climates (COPd) | | 1.40 |
| Tj = operating temperature limit under moderate climatic conditions (COPd) | | 2.00 |
| Tj = operating temperature limit in warmer climates (COPd) | | 2.20 |
| For air/water heat pumps: Tj = -15 °C (if TOL < -20 °C) (COPd) | | 0.00 |
| Operating temperature limit in colder climates (TOL) | °C | -15 |
| Operating temperature limit in moderate climates (TOL) | °C | -5 |
| Operating temperature limit in warmer climates (TOL) | °C | 2 |
| Heating water operating temperature limit in colder climates (WTOL) | °C | 60 |
| Heating water operating temperature limit (WTOL) | °C | 60 |
| Heating water operating temperature limit in warmer climates (WTOL) | °C | 60 |
| Power consumption, OFF state (Poff) | W | 17 |
| Power consumption, thermostat OFF state (PTO) | W | 30 |
| Standby power consumption (PSB) | W | 17 |
| Power consumption, operating state, with crankcase heating (PCK) | W | 5 |
| Booster heater heating output in colder climates (Psup) | kW | 11.0 |
| Booster heater heating output in moderate climate (Psup) | kW | 8.0 |
| Booster heater heating output in warmer climates (Psup) | kW | 0.0 |
| Type of energy supply, booster heater | | electric |
| Power control | | variable |
| Sound power level external | dB(A) | 57 |
| Annual energy consumption in colder climates for average temperature applications (QHE) | kWh/a | 10193 |
| Annual energy consumption in moderate climates for average temperature applications (QHE) | kWh/a | 4865 |
| Annual energy consumption in warmer climates for average temperature applications (QHE) | kWh/a | 2048 |
| Flow rate, heat source side | m ³ /h | 2200 |
| Load profile | | L |
| Daily power consumption (Qelec) | kWh | 4.45 |
| Annual power consumption in colder climates (AEC) | kWh/a | 1689 |
| Annual power consumption in moderate climates (AEC) | kWh/a | 1526 |
| Annual power consumption in warmer climates (AEC) | kWh/a | 1181 |
| Energy efficiency for DHW heating (Γ_{wh}) under moderate climatic conditions | % | 111 |
| Special measures | For all special measures to be taken during assembly, installation or maintenance of the room heater, see the installation instructions | |